

BRAZORIA COUNTY ADDENDUM NUMBER 5

ITB #10-02 CONSTRUCTION OF THE EAST ANNEX ADULT PROBATION DEPARTMENT

PLEASE INCLUDE THIS SIGNED ADDENDUM WITH YOUR SEALED ITB PACKAGE.

This Addendum modifies the ITB #10-02 Construction of the East Annex Adult Probation Department package as follows:

1. Definitions: All definitions set forth in the Contract shall have the same meaning unless stated otherwise in this Addendum.
2. The following questions has been submitted for clarification:

- 2.1 Vendor Question: "On page M4.0 of the amended drawing keyed note #9 addresses the replacement of two to the existing 5 ton roof top units. My question is what are the requirements regarding any accessories and capacities. Also, under keyed note #3, where is states to replace the existing 8 roof top units under the base bids, there is no reference to size or any other information available."

Brazoria County Answer: In regards to keyed note #9, the existing 5 ton RTU's (roof top units) or (package units) will be replaced with the same type and capacity, for example another similar new energy efficient 5 ton unit. Same would apply to keyed note #3. The existing 10 ton RTU's will be replaced with similar new 10 ton units. Basically replace old to new however same spec's on all RTU's in both the base and the alternate.

2.2 BRAZORIA COUNTY STATEMENT:

Please note the bid open / due date is Thursday, November 5, 2009 at 10:00 a.m. Due to the timeframe, this will be the last addendum posted. There will be no further request for clarifications accepted.

3. All other terms and conditions of the ITB are to remain unchanged.

Please refer any questions regarding this ITB to the Brazoria County Purchasing Department at (979) 864-1282 or natashas@brazoria-county.com.

LEGAL NAME OF CONTRACTING COMPANY

TELEPHONE NUMBER

FACSIMILE NUMBER

SIGNATURE

NAME AND TITLE PRINTED